



www.GotBigWater.com

Drafting Operations


**Recirculating Line Using
Front Bumper Discharge**

A Recirculating Line Absent the Hose



Facts & Figures...

- This 1500 gpm pumper was set up to fill tankers during a water shuttle drill.
- The pump operator elected to simply put a handline nozzle on the front discharge in order to create a recirculating line to help maintain the pump's prime.
- This quick thinking kept hose out of the narrow roadway allowing tankers better access.



www.GotBigWater.com

*This program was developed by
GBW Associates, LLC
© 2007*

*No part may be used or copied
without expressed written consent.*

*For more information contact us at
info@gotbigwater.com*